



**CHINA QUALITY CERTIFICATION CENTRE**  
**CERTIFICATE OF CONFORMITY**

**Certificate No.: CE170303005261-H1**

**Product** Air Circuit Breaker

**Applicant** Sassin International Electric Shanghai Co.,Ltd.  
No.2588 Jinhai Road, Shanghai, P.R.China

**Type/Model** 3SW68-4000N,3SW68-4000H

**Technical data** See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 03601-A-19D0139-S-A;03601-A-19D0139-S-B, the submitted sample(s) of the above item complies with:

**EN 60947-2:2006**

and fulfills testing requirements of the European Directive:  
**2014/35/EU**

**Valid from:** Jan.15,2020

**Valid until:** Jan.15,2023

**President:**

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

**CE 0010411**



CHINA QUALITY CERTIFICATION CENTRE  
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE170303005261-H1

3SW68-4000N,3SW68-4000H;  
Ui:1000V,Ue:AC400V/690V,  
In: 2000A,2500A,2900A,3200A,3600A,4000A,  
Electronic over-current release,  
Ics/Icu:3SW68-4000N:85/85kA(AC400V),75/75kA(AC690V);  
3SW68-4000H:100/120kA(AC400V),85/85kA(AC690V);  
Icw:3SW68-4000N:85kA/1s(AC400V),75kA/1s(AC690V),  
3SW68-4000H:100kA/1s(AC400V),85kA/1s(AC690V),  
Utilization Category:B, 3P,4P,  
Auxiliary circuits: Ith:10A, 4NO4NC,  
AC-15:Ue/Ie: AC415V/2A,AC400V/0.75A;  
DC-13:Ue/Ie: DC250V/ 0.3A,DC220V/0.27A;  
Annex N:Undervoltage release:SQ3-1:AC230V,AC400V.

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>