



**CHINA QUALITY CERTIFICATION CENTRE**  
**CERTIFICATE OF CONFORMITY**

Certificate No.: CE170303005262-H1

**Product**

Air Circuit Breaker

**Applicant**

Sassin International Electric Shanghai Co.,Ltd.

No.2588 Jinhai Road, Shanghai, P.R.China

**Type/Model**

3SW68-2500N,3SW68-2500N/4,3SW68-2500H,3SW68-2500H/4

**Technical data**

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 03601-A-19D0140-S-A;03601-A-19D0140-S-B, the submitted sample(s) of the above item complies with:

**EN 60947-2:2006**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

**Valid from:** Jan.15,2020

**Valid until:** Jan.15,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0010412



CHINA QUALITY CERTIFICATION CENTRE  
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE170303005262-H1

3SW68-2500N,3SW68-2500N/4,3SW68-2500H,3SW68-2500H/4;  
Ui:1000V;Ue:AC400V/690V;Uimp:12kV;  
In:630A,800A,1000A,1250A,1600A,2000A,2500A;  
Over-current Release Type: Electronic;  
3SW68-2500N:AC400V:Ics:70kA;Icu:70kA;Icw:70kA/1s;  
AC690V:Ics:55kA;Icu:55kA;Icw:55kA/1s;  
3SW68-2500H:AC400V:Ics:85kA;Icu:85kA;Icw:85kA/1s;  
AC690V:Ics:65kA;Icu:65kA;Icw:65kA/1s;  
Utilization Category:B;3P,4P(3 protected poles with an uninterrupted neutral pole);  
Auxiliary Circuit:(4NO,4NC);  
Ith:10A;  
AC-15:Ue/Ie:AC415V/2A,AC400V/0.75A;  
DC-13:Ue/Ie:DC250V/0.3A,DC220V/0.27A;  
Annex N:Undervoltage release:SQ3-1;Us:AC230V,AC400V;

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>