



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE170303005263-H1

Product Air Circuit Breaker

Applicant Sassin International Electric Shanghai Co.,Ltd.
No.2588 Jinhai Road, Shanghai, P.R.China

Type/Model 3SW68-1600N,3SW68-1600H

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 03601-A-19D0141-S, the submitted sample(s) of the above item complies with:

EN 60947-2:2006

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Jan.15,2020

Valid until: Jan.15,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0010416



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE170303005263-H1

3SW68-1600N,3SW68-1600H
Ui:1000V;Ue:AC400V,AC690V;
In:200A,400A,630A,800A,1000A,1250A,1600A;
Electronic over-current release;
Utilization Category:B;
3SW68-1600N:AC400V:Ics:42kA,Icu:55kA,Icw:42kA/1s,50kA/0.5s;
AC690V:Ics:25kA,Icu:25kA,Icw:25kA/1s;
3SW68-1600H:AC400V:Ics:55kA,Icu:65kA,Icw:50kA/1s,55kA/0.5s;
AC690V:Ics:35kA,Icu:35kA,Icw:35kA/1s;
3P,4P
Auxiliary circuits:SFK3(4NO4NC);
Ith:10A;
AC-15:Ue:AC400V/Ie:0.75A;
DC-13:Ue:DC220V/Ie:0.27A.
Annex N: Undervoltage release:
Model:SQ3-1;
Us:AC230V,AC400V;

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>